




Cautions and Warnings

- This product must be installed in accordance with the applicable installation code by a licensed electrician familiar with the construction and operation of the product and hazards involved.
- Power must be OFF when connecting the fixture. "hot plugging" the light engine and driver will damage the LED source.
- The light engine is low voltage and is factory wired to the driver DO NOT CONNECT LIGHT ENGINE TO MAINS AC POWER.
- **4.** LEDs should be protected from dust and debris during during installation and maintenance.
- Polarity is important. Black must be connected to black and red connected to red.
- 6. Not designed for use as temporary lighting.

Mount housing to structure using included hanger bars. Mount housing so that face of throat is coplanar with the face of the ceiling. HANGER BARS (2) SETS HOUSING FRAMING MEMBER BUTTERFLY BRACKET (2) THROAT VIEW A - A







** LED'S SHOULD BE PROTECTED FROM DUST AND DEBRIS DURING INSTALLATION AND MAINTENANCE


Click here to read full Care and Maintenance

Page 1 of 2



Step E Install flange by threading flange onto throat. THROAT FLANGE

Step F Attach connector, install lamp head through aperture and affix to top of inside of housing. APERTURE CONNECTOR LAMP HEAD



Page 2 of 2